



Építésügyi Minőségellenőrző Innovációs Kht.
Központi Laboratórium
Aktív Tűzvédelmi Eszközöket Vizsgáló Laboratóriuma

Npc for Quality Control and
Innovation in Building
Fire Testing Laboratory

Central Laboratory: 1113 Budapest, Diószegi út 37.
Active Fire Protection Laboratory:
2000 Szentendre, Dózsa György út 26.

Phone: (36-1) 372-6113
Phone: (36-26) 310-526

No.: TMT-11/2007
(identical TMT-2027/2005)

CERTIFICATE

on the

FIRE SAFETY CONFORMITY

of a technical product

This Certificate is issued by ÉMI Kht. as an attestation body by appointment
No. 1-A/1014/2004
(16 December 2004) of the Minister of Interior,

at the request of


TELEFIRE FIRE & GAS DETECTORS LTD.
5 Halapid St. P.O.B. 7036 Petach-Tikva IL-49250 Israel

This Certificate of Conformity is based on the test results outlined in the attached TEST REPORT.
Identification marking of technical product (brand name, type, marking):

**TPB-800 ASR ANALOG ADDRESSABLE INDOOR MANUAL
FIRE ALARM CALL POINT AND
TPB-800 ASY ANALOG ADRESSABLE INDOOR MANUAL
EXTINGUISHING CALL POINT**

This CERTIFICATE OF CONFORMITY (FIRE SAFETY) is valid until 18th of October 2010.

Budapest, 23th of March 2007.


Dr. Bánky Tamás
Scientific Director

Seal



ÉMI Kht.'s Central Laboratory, Fire Testing Laboratory

- has been accredited under No. NAT-1-1100/2006 by the National Accreditation Body, in accordance with Hungarian Standard MSZ EN ISO/IEC 17025:2001; and
- it is a full rights member of EGOLF (European Group of Organisation for Fire Testing, Inspection and Certification).

Product manufacturer: TELEFIRE Fire & Gas Detectors Ltd.
5 Halapid St. P.O.B. 7036 Petach-Tikva
IL-49250, Israel

Distributor: NSL Security Ltd.,
H-1025 Budapest Özgida utca 15/4, Hungary

Identification of testing facilities:

ÉMI Kht. Central Laboratory (H-1113 Budapest, Diószegi út 37)
Active Fire Protection Laboratory (H-2000 Szentendre, Dózsa György út 26)

Standards observed in testing the product:

- MSZ EN54-1:2002 Fire detection and fire alarm systems. Part 1: Introduction,
- MSZ EN 54-11:2003 Fire detection and fire alarm systems. Part 11: Manual call point,
- 2/2002.(1.23.) BM –Decree of Minister of the Interior

Brief description and technical data of the products:

The TPB-800ASR is an analog addressable call point push-button. It consists of a standard alarm call point unit and an analog addressable interface module mounted behind the front part of the break-glass section. The address is assigned to the TPB-800ASR by using the PROG-4000 Programmer.

The TPB-800ASR is connected to the SLC loop in the same way as an analog detector.

The TPB-800ASY is an analog addressable extinguishing push-button. It is mechanically and electronically identical to the TPB-800ASR, with the exception of its bright yellow color to indicate its function.

TPB-800ASR and TPB-800ASY are configured as "push button", but typically they are configured so that pressing the TPB-800ASY manual extinguishing call point activates the system extinguishers, whilst the TPB-800ASR is treated as an alarm.

Nominal Voltage:	min. 12 VDC (max. 50 VDC)
Load Current:	max. 3 A
IP Protection:	IP 44 — Indoor
Dimension [mm]:	85 × 85 × 22

Field of application of the product (96/577/EC): *Fire detection/alarm components —
Manual call point*

Identification marking of technical documents: M-800/2005

Technical conditions of applying the product safely:

The technical conditions are identified in section M-800/2004 of the relevant No. 2nd part Test Report. No. TMT-11/2007 Certificate of Conformity (Fire Safety) covers a product which fully complies with the data and technical characteristics featuring in the Test Report marked 2nd Part and dated 18th of October 2005, provided that the other conditions of application identified in section 2nd Part of the Test Report are met. During the life of this Certificate of Conformity, ÉMI Kht. is entitled to inspect the product in the manufacturing and/or distribution process, with expenses paid by the customer.


Antalné Lőrök Noémi
Head of Laboratory