



**ÉMI Építészeti Minőségellenőrző Innovációs
Nonprofit Kft.
Központi Laboratórium
Tűzvédelmi Szakági Laboratórium**

**ÉMI Non-Profit Limited Liability
Company for Quality and
Innovation in Building
Fire Testing Laboratory**

Central Laboratory: 1113 Budapest, Diószegi út 37.

Phone: (36-1) 372-6113

Active Fire Testing Laboratory:

Phone: (36-26) 310-526

2000 Szentendre, Dózsa György út 26.

No. TMT-22/2011

CERTIFICATE

on the
FIRE SAFETY CONFORMITY
of a technical product

This Certificate is issued by ÉMI Nonprofit Kft. as an attestation body by appointment
No. 1-A/1014/2004
16 December 2004) of the Minister of Interior,

at the request of

**TEF NEDERLAND BV
NL-2921 LH KRIMPEN AAN DEN IJSSEL,
SLIKSLOOTSTRAAT 9 A**

This Certificate of Conformity is based on the test results outlined in the attached TEST REPORT.
Identification marking of technical product (brand name, type, marking):

**NET-MPX-REL AND GFE-MPX-REL ZONE
INDICATING RELAY**

This CERTIFICATE OF CONFORMITY (FIRE SAFETY) is valid until 15. July 2016

Budapest, 5 of July 2011

Seal

Dr Matolcsy Károly
Scientific Director



MSZT CERT
503/0933(2)-857(2)

ÉMI Nonprofit Kft.'s Central Laboratory,
Fire Testing Laboratory

- has been accredited under No. NAT-1-1110/2010 by the National Accreditation Body, in accordance with Hungarian Standard MSZ EN ISO/IEC 17025:2005; and
- it is a full rights member of EGOLF (European Group of Organisation for Fire Testing, Inspection and Certification).

KBiA-Xa-11-2010.01.17.

Product manufacturer: GLOBAL FIRE EQUIPMENT Ltd.
Urb. Vale da Amoreia 16-17 Porta A/ 85-34 FARO, Portugal

Distributor: TEF Nederland BV
NL-2921 LH Krimpen aan den IJssel, Slikslootstraat 9 a

Identification of testing facilities:

ÉMI Nonprofit Kft. Central Laboratory (H-1113 Budapest, Diószegi út 37)
Fire Testing Laboratory (H-2000 Szentendre, Dózsa György út 26)

Standards observed in testing the product:

- MSZ EN 54-13:2005 Fire detection and fire alarm systems. Part 13: Compatibility assessment of system components
- MSZ EN 54-18:2006 Fire detection and fire alarm systems. Part 18: Input/output devices
- 9/2008.(II.22.) ÖTM –Decree for the Ministry of the Local Government and Regional Development

Brief description and technical data of the products:

NET MPX-REL zone display relay type REL Global Fire Equipment Junior and Juno-Net analogue fire panels. Operating modes: 8 zone fire indicator, fault zones and fire display, eight kinds of system status: fire, failure to signal, a test mode, out, off siren, siren turns on and off screen.

GFE-MPX-REL zone indicator relay Orion conventional fire panels used for zone display with 8 LED display of the individual zones of fire alarm status display, and eight relay outputs for each zone fire alarm condition to control, and a delayed zone from 00 to 10 minutes can be selected delay can be set. 4 and 8 zone version is

	J-NET-MPX-REL	GFE-MPX-REL
Power supply (nominal) [VDC]:	24	
Current - quiescent [mA]:	7 without active relay	
Current - alarm [mA]:	7 + 15 as active relay	
Zoneswitching:	D.I.L. switch	—
Dimensions[mm]:	88 × 72,5 × 18	
Weight [g]:	95 (8 zone)	60 (4 one), 95 (8 zone)
Environment:	0...+50 °C / 95% (no condensation)	
Timing:	—	15 setting 0... 10 min

Field of application of the product: (96/577/EK): *Fire detection/alarm components* — Input/output devices

Identification of technical documents: M-199/2008; TMT-10/2008

Technical conditions of applying the product safely:

The technical conditions are identified in section 2nd and 4th of the relevant No. M-199/2008 Test Report. No. **TMT-22/2011** Certificate of Conformity (Fire Safety) covers a product which fully complies with the data and technical characteristics featuring in the Test Report marked . M-199/2008 and dated 31-03-2008 provided that the other conditions of application identified in section 2nd of the Test Report are met.

During the life of this Certificate of Conformity, ÉMI Nonprofit Kft. is entitled to inspect the product in the manufacturing and/or distribution process, with expenses paid by the customer.

Noémi LÓRIK
Deputy Head of Active Fire
Testing Laboratory

Péter GEIER
Deputy Head of Division
of Fire Protection